

**TITLE 18**

**WATER AND SEWERS**

**CHAPTER**

**1. UTILITY DISTRICTS.**

**CHAPTER 1**

**UTILITY DISTRICTS<sup>1</sup>**

**SECTION**

18-101. Minimum diameter of water mains.

18-102. Maximum distance between fire hydrants.

**18-101. Minimum diameter of water mains.** It shall be unlawful for any water main to be laid within the corporate limits by any public utility, utility district, or waterworks company which is less than six (6) inches in diameter by inside measurements. (1992 Code, § 19-301)

**18-102. Maximum distance between fire hydrants.** It shall be unlawful for any public utility, utility district, or waterworks company to install or erect fire hydrants in the business districts of the municipality so that the distance from one fire hydrant to the next nearest fire hydrant exceeds five hundred (500) feet and in the residential districts of the municipality so that the distance from one fire hydrant exceeds one thousand (1,000) feet. (1992 Code, § 19-302)

---

<sup>1</sup>Municipal code references

Building and utility codes: title 12

Cross connections: title 16.

Gas is furnished to the municipality and its inhabitants by the Hawkins County Gas Utility District of Hawkins County, Tennessee pursuant to a franchise granted by the municipality, dated November 7, 1960, a copy of which is of record in the recorder's office.

South Central Bell is authorized to use the public streets of the municipality for the purpose of erecting, constructing, maintaining, and operating telephone and telegraph lines pursuant to an ordinance dated May 6, 1963 and letter of acceptance dated June 27, 1963, which are of record in the recorder's office.