

TITLE 18**WATER AND SEWERS¹****CHAPTER**

1. WATER AND SEWER SYSTEM ADMINISTRATION.
2. GENERAL WASTEWATER REGULATIONS.
3. CROSS-CONNECTIONS, AUXILIARY INTAKES, ETC.

CHAPTER 1**WATER AND SEWER SYSTEM ADMINISTRATION****SECTION**

- 18-101. Application and scope.
- 18-102. Definitions.
- 18-103. Application and contract for service.
- 18-104. Service charges for temporary service.
- 18-105. Connection charges.
- 18-106. Water and sewer main extensions.
- 18-107. Water and sewer main extension variances.
- 18-108. Meters.
- 18-109. Meter tests.
- 18-110. Multiple services through a single meter.
- 18-111. Customer billing and payment policy.
- 18-112. Termination or refusal of service.
- 18-113. Termination of service by customer.
- 18-114. Access to customers' premises.
- 18-115. Inspections.
- 18-116. Customer's responsibility for system's property.
- 18-117. Customer's responsibility for violations.
- 18-118. Supply and resale of water.
- 18-119. Unauthorized use of or interference with water supply.
- 18-120. Limited use of unmetered private fire line.
- 18-121. Damages to property due to water pressure.
- 18-122. Liability for cutoff failures.
- 18-123. Restricted use of water.

¹Municipal code references

Building, utility and residential codes: title 12.

Refuse disposal: title 17.

18-124. Interruption of service.

18-125. Schedule of rates.

18-101. Application and scope. The provisions of this chapter are a part of all contracts for receiving water and sewer service from the town and shall apply whether the service is based upon contract, agreement, signed application, or otherwise.

18-102. Definitions. (1) "Customer" means any person, firm, or corporation who receives water and/or sewer service from the town under either an express or implied contract.

(2) "Dwelling" means any single residential unit or house occupied for residential purposes. Each separate apartment unit, duplex unit or other multiple dwelling unit shall be considered a separate dwelling.

(3) "Premise" means any structure or group of structures operated as a single business or enterprise, provided, however, the term "premise" shall not include more than one (1) dwelling.

(4) "Service line" shall consist of the pipe line extending from any water or sewer main of the town to private property. Where a meter and meter box are located on private property, the service line shall be construed to include the pipe line extending from the city's/town's water main to and including the meter and meter box.

18-103. Application and contract for service. Each prospective customer desiring water and/or sewer service will be required to sign a standard form contract and pay a non-refundable connection fee of fifty dollars (\$50.00) for homeowners and one hundred fifty dollars (\$150.00) for non-homeowners. If, for any reason, a customer, after signing a contract for service, does not take such service by reason of not occupying the premises or otherwise, he shall reimburse the town for the expense incurred by reason of its endeavor to furnish such service.

The receipt of a prospective customer's application for service shall not obligate the town to render the service applied for.

18-104. Service charges for temporary service. Customers requiring temporary service shall pay all costs for connection and disconnection incidental to the supplying and removing of service in addition to the regular charge for water and/or sewer service.

18-105. Connection charges. Service lines will be laid by the town from its mains to the property line at the expense of the applicant for service. The location of such lines will be determined by the town.

Before a new water or sewer service line will be laid by the town, the applicant shall pay a nonrefundable connection charge of four hundred dollars

(\$400.00) for a new sewer line and six hundred dollars (\$600.00) for a new water line.

When a service line is completed, the town shall be responsible for the maintenance and upkeep of such service line from the main to and including the meter and meter box, and such portion of the service line shall belong to the town. The remaining portion of the service line beyond the meter box (or property line, in the case of sewers) shall belong to and be the responsibility of the customer.

18-106. Water and sewer main extensions.¹ Persons desiring water and/or sewer main extensions must pay all of the cost of making such extensions.

All such extensions shall be installed either by town forces or by other forces working directly under the supervision of the town in accordance with plans and specifications prepared by an engineer registered with the State of Tennessee.

Upon completion of such extensions and their approval by the town, such water and/or sewer mains shall become the property of the town. The persons paying the cost of constructing such mains shall execute any written instruments requested by the town to provide evidence of the city's/town's title to such mains. In consideration of such mains being transferred to it, the town shall incorporate said mains as an integral part of the municipal water and sewer systems and shall furnish water and sewer service therefrom in accordance with these rules and regulations, subject always to such limitations as may exist because of the size and elevation of the mains.

18-107. Water and sewer main extension variances. Whenever the board of mayor and aldermen is of the opinion that it is to the best interest of the town and its inhabitants to construct a water and/or sewer main extension without requiring strict compliance with the preceding section, such extension may be constructed upon such terms and conditions as shall be approved by the board of mayor and aldermen.

The authority to make water and/or sewer main extensions under the preceding section is permissive only and nothing contained therein shall be construed as requiring the town to make such extensions or to furnish service to any person or persons.

18-108. Meters. All meters shall be installed, tested, repaired, and removed only by the town.

¹Municipal code reference

Construction of building sewers: title 18, chapter 2.

No one shall do anything which will in any way interfere with or prevent the operation of a meter. No one shall tamper with or work on a water meter without the written permission of the town. No one shall install any pipe or other device which will cause water to pass through or around a meter without the passage of such water being registered fully by the meter.

18-109. Meter tests. The town will, at its own expense, make routine tests of meters when it considers such tests desirable.

In testing meters, the water passing through a meter will be weighed or measured at various rates of discharge and under varying pressures. To be considered accurate, the meter registration shall check with the weighed or measured amounts of water within the percentage shown in the following table:

<u>Meter Size</u>	<u>Percentage</u>
5/8", 3/4", 1", 2"	2%
3"	3%
4"	4%
6"	5%

The town will also make tests or inspections of its meters at the request of the customer. However, if a test requested by a customer shows a meter to be accurate within the limits stated above, the customer shall pay a meter testing charge in the amount stated in the following table:

<u>Meter Size</u>	<u>Test Charge</u>
5/8", 3/4", 1"	\$12.00
1-1/2", 2"	15.00
3"	18.00
4"	22.00
6" and over	30.00

If such test shows a meter not to be accurate within such limits, the cost of such meter test shall be borne by the town.

18-110. Multiple services through a single meter. No customer shall supply water service to more than one dwelling, premise, duplex unit, apartment or other multiple dwelling unit from a single service line and meter without first obtaining the written permission of the town.

Where the town allows more than one (1) dwelling, premise, duplex unit, apartment or other multiple dwelling unit to be served through a single service line and meter, the amount of water used by all the dwellings, premises, duplex units, apartments or other multiple dwelling units served through a single service line and meter shall be allocated to each separate dwelling, premise, duplex unit, apartment or other multiple dwelling unit served. The water

charge of each such dwelling, premise, duplex unit, apartment or other multiple dwelling unit thus served shall be computed just as if each such dwelling, premise, duplex unit, apartment or other multiple dwelling unit had received through a separately metered service the amount of water so allocated to it, such computation to be made at the city's/town's applicable water rates schedule, including the provisions as to minimum bills. The separate charges for each dwelling, premise, duplex unit, apartment or other multiple dwelling unit served through a single service line meter shall then be added together, and the sum thereof shall be billed to the customer in whose name the service is supplied.

18-111. Customer billing and payment policy. Water and sewer bills shall be rendered monthly and shall designate a standard net payment period for all members of not less than twelve (12) days after the date of the bill. Failure to receive a bill will not release a customer from payment obligation. There is established for all members a late payment charge not to exceed ten percent (10%) for any portion of the bill paid after the net payment period.

Payment must be received in the water and sewer department no later than 4:00 P.M. on the due date. If the due date falls on Saturday, Sunday, or a holiday, net payment will be accepted if paid on the next business day no later than 4:00 P.M.

If a meter fails to register properly, or if a meter is removed to be tested or repaired, or if water is received other than through a meter, the town reserves the right to render an estimated bill based on the best information available.

18-112. Termination or refusal of service. (1) Basis of termination or refusal. The town shall have the right to discontinue water and sewer service or to refuse to connect service for a violation of, or a failure to comply with, any of the following:

- (a) These rules and regulations, including the nonpayment of bills.
- (b) The customer's application for service.
- (c) The customer's contract for service.

The right to discontinue service shall apply to all water and sewer services received through collective single connections or services, even though more than one (1) customer or tenant is furnished services therefrom, and even though the delinquency or violation is limited to only one (1) such customer or tenant.

(2) Termination of service. Reasonable written notice shall be given to the customer before termination of water service according to the following terms and conditions:

(a) Written notice of termination (cut-off) shall be given to the customer at least five (5) days prior to the scheduled date of termination. The cut-off notice shall specify the reason for the cut-off, and

- (i) The amount due, including other charges.
- (ii) The last date to avoid service termination.
- (iii) Notification of the customer's right to a hearing prior to service termination, and, in the case of nonpayment of bills, of the availability of special counseling for emergency and hardship cases.

(b) In the case of termination for nonpayment of bills, the employee carrying out the termination procedure will attempt before disconnecting service to contact the customer at the premises in a final effort to collect payment and avoid termination. If the customer is not at home, service may be left connected for one (1) additional day and a further notice left at a location conspicuous to the customer.

(c) Hearings for service termination, including for nonpayment of bills, will be held by appointment at the company office between the hours of 8:00 A.M. and 4:30 P.M. on any business day, or by special request and appointment a hearing may be scheduled outside those hours.

(d) Termination will not be made on any preceding day when the water and sewer department is scheduled to be closed.

(e) If a customer does not request a hearing, or, in the case of nonpayment of a bill, does not make payment of the bill, or does not otherwise correct the problem that resulted in the notice of termination in a manner satisfactory to the water and sewer department, the same shall proceed on schedule with service termination.

(f) Service termination for any reason shall be reconnected only after the payment of all charges due or satisfactory arrangements for payment have been made, or the correction of the problem that resulted in the termination of service in a manner satisfactory to the water and sewer department, plus the payment of a reconnection charge of twenty-five dollars (\$25.00).

18-113. Termination of service by customer. Customers who have fulfilled their contract terms and wish to discontinue service must give at least three (3) days written notice to that effect unless the contract specifies otherwise. Notice to discontinue service prior to the expiration of a contract term will not relieve the customer from any minimum or guaranteed payment under such contract or applicable rate schedule.

When service is being furnished to an occupant of premises under a contract not in the occupant's name, the town reserves the right to impose the following conditions on the right of the customer to discontinue service under such a contract:

(1) Written notice of the customer's desire for such service to be discontinued may be required; and the town shall have the right to continue such service for a period of not to exceed ten (10) days after receipt of such written notice, during which time the customer shall be responsible for all charges for such service. If the town should continue service after such ten (10) day period subsequent to the receipt of the customer's written notice to discontinue service, the customer shall not be responsible for charges for any service furnished after the expiration of the ten (10) day period.

(2) During the ten (10) day period, the occupant of premises to which service has been ordered discontinued by a customer other than such occupant, may be allowed by the town to enter into a contract for service in the occupant's own name upon the occupant's complying with these rules and regulations with respect to a new application for service.

18-114. Access to customers' premises. The city's/town's identified representatives and employees shall be granted access to all customers' premises at all reasonable times for the purpose of reading meters, for testing, inspecting, repairing, removing, and replacing all equipment belonging to the town, and for inspecting customers' plumbing and premises generally in order to secure compliance with these rules and regulations.

18-115. Inspections. The town shall have the right, but shall not be obligated, to inspect any installation or plumbing system before water and/or sewer service is furnished or at any later time. The town reserves the right to refuse service or to discontinue service to any premises not in compliance with any special contract, these rules and regulations, or other requirements of the town.

Any failure to inspect or reject a customer's installation or plumbing system shall not render the town liable or responsible for any loss or damage which might have been avoided had such inspection or rejection been made.

18-116. Customer's responsibility for system's property. Except as herein elsewhere expressly provided, all meters, service connections, and other equipment furnished by or for the town shall be and remain the property of the town. Each customer shall provide space for and exercise proper care to protect the property of the town on his premises. In the event of loss or damage to such property arising from the neglect of a customer to care for it properly, the cost of necessary repairs or replacements shall be paid by the customer.

18-117. Customer's responsibility for violations. Where the town furnishes water and/or sewer service to a customer, such customer shall be responsible for all violations of these rules and regulations which occur on the premises so served. Personal participation by the customer in any such violations shall not be necessary to impose such personal responsibility on him.

18-118. Supply and resale of water. All water shall be supplied within the town exclusively by the town, and no customer shall, directly or indirectly, sell, sublet, assign, or otherwise dispose of the water or any part thereof except with written permission from the town.

18-119. Unauthorized use of or interference with water supply. No person shall turn on or turn off any of the city's/town's stop cocks, valves, hydrants, spigots, or fire plugs without permission or authority from the town.

18-120. Limited use of unmetered private fire line. Where a private fire line is not metered, no water shall be used from such line or from any fire hydrant thereon, except to fight fire or except when being inspected in the presence of an authorized agent of the town.

All private fire hydrants shall be sealed by the town, and shall be inspected at regular intervals to see that they are in proper condition and that no water is being used therefrom in violation of these rules and regulations. When the seal is broken on account of fire, or for any other reason, the customer taking such service shall immediately give the town a written notice of such occurrence.

18-121. Damages to property due to water pressure. The town shall not be liable to any customer for damages caused to his plumbing or property by high pressure, low pressure, or fluctuations in pressure in the city's/town's water mains.

18-122. Liability for cutoff failures. The city's/town's liability shall be limited to the forfeiture of the right to charge a customer for water that is not used but is received from a service line under any of the following circumstances:

(1) After receipt of at least ten (10) days' written notice to cut off water service, the town has failed to cut off such service.

(2) The town has attempted to cut off a service but such service has not been completely cut off.

(3) The town has completely cut off a service but subsequently the cutoff develops a leak or is turned on again so that water enters the customer's pipes from the city's/town's main.

Except to the extent stated above, the town shall not be liable for any loss or damage resulting from cutoff failures. If a customer wishes to avoid possible damage for cutoff failures, the customer shall rely exclusively on privately owned cutoffs and not on the city's/town's cutoff. Also, the customer (and not the town) shall be responsible for seeing that his plumbing is properly drained and is kept properly drained, after his water service has been cut off.

18-123. Restricted use of water. In times of emergencies or in times of water shortage, the town reserves the right to restrict the purposes for which water may be used by a customer and the amount of water which a customer may use.

18-124. Interruption of service. The town will endeavor to furnish continuous water and sewer service, but does not guarantee to the customer any fixed pressure or continuous service. The town shall not be liable for any damages for any interruption of service whatsoever.

In connection with the operation, maintenance, repair, and extension of the municipal water and sewer systems, the water supply may be shut off without notice when necessary or desirable, and each customer must be prepared for such emergencies. The town shall not be liable for any damages from such interruption of service or for damages from the resumption of service without notice after any such interruption.

18-125. Schedule of rates.¹ All water and sewer service shall be furnished under such rate schedules as the town may from time to time adopt by appropriate ordinance.²

¹Administrative ordinances are of record in the office of the recorder.

²State law reference
Tennessee Code Annotated, § 7-35-414(b).

CHAPTER 2

GENERAL WASTEWATER REGULATIONS

SECTION

- 18-201. Purpose and policy.
- 18-202. Administrative
- 18-203. Definitions.
- 18-204. Proper waste disposal required.
- 18-205. Private domestic wastewater disposal.
- 18-206. Connection to public sewers.
- 18-207. Septic tank effluent pump or grinder pump wastewater systems.
- 18-208. Regulation of holding tank waste disposal or trucked in waste.
- 18-209. Discharge regulations.

18-201. Purpose and policy. This chapter sets forth uniform requirements for users of the Town of Trezevant, Tennessee, wastewater treatment system and enables the town to comply with the Federal Clean Water Act and the state Water Quality Control Act and rules adopted pursuant to these acts. The objectives of this chapter are:

- (1) To protect public health,
- (2) To prevent the introduction of pollutants into the municipal wastewater treatment facility, which will interfere with the system operation;
- (3) To prevent the introduction of pollutants into the wastewater treatment facility that will pass through the facility, inadequately treated, into the receiving waters, or otherwise be incompatible with the treatment facility;
- (4) To protect facility personnel who may be affected by wastewater and sludge in the course of their employment and the general public;
- (5) To promote reuse and recycling of industrial wastewater and sludge from the facility;
- (6) To provide for fees for the equitable distribution of the cost of operation, maintenance, and improvement of the facility; and
- (7) To enable the town to comply with its National Pollution Discharge Elimination System (NPDES) permit conditions, sludge and biosolid use and disposal requirement, and any other Federal or State industrial pretreatment rules to which the facility is subject.

In meeting these objectives, this chapter provides that all persons in the service area of the Town of Trezevant must have adequate wastewater treatment either in the form of a connection to the municipal wastewater treatment system or, where the system is not available, an appropriate private disposal system.

This chapter shall apply to all users inside or outside the town who are, by implied contract or written agreement with the town, dischargers of applicable wastewater to the wastewater treatment facility. Chapter 2 provides

for the issuance of permits to system users, for monitoring, compliance, and enforcement activities; establishes administrative review procedures for industrial users or other users whose discharge can interfere with or cause violations to occur at the wastewater treatment facility. Chapter 2 details permitting requirements including the setting of fees for the full and equitable distribution of costs resulting from the operation, maintenance, and capital recovery of the wastewater treatment system and from other activities required by the enforcement and administrative program established herein.

18-202. Administrative. Except as otherwise provided herein, the local administrative officer of the town shall administer, implement, and enforce the provisions of this chapter.

18-203. Definitions. Unless the context specifically indicates otherwise, the following terms and phrases, as used in this chapter, shall have the meanings hereinafter designated:

(1) "Administrator." The administrator or the United States Environmental Protection Agency.

(2) "Act or the Act." The Federal Water Pollution Control Act, also known as the Clean Water Act, as amended and found in 33 U.S.C. § 1251, *et seq.*

(3) "Approval authority." The Tennessee Department of Environment and Conservation, Division of Water Pollution Control.

(4) "Authorized or duly authorized representative" of industrial user:

(a) If the user is a corporation:

(i) The president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any person who performs similar policy or decision-making functions for the corporation; or

(ii) The manager of one or more manufacturing, production, or operating facilities, provided the manager is authorized to make management decisions that govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiate and direct other comprehensive measures to assure long-term environmental compliance with environmental laws and regulations; can insure that the necessary systems are established or actions taken to gather complete and accurate information for individual wastewater discharge permit requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

(b) If the user is a partnership or sole proprietorship: a general partner or proprietor, respectively.

(c) If the user is a federal, state, or local governmental agency: a director or highest official appointed or designated to oversee the operation and performance of the activities of the governmental facility, or their designee.

(d) The individual described in paragraphs (a)-(c), above, may designate a duly authorized representative if the authorization is in writing, the authorization specifies the individual or position responsible for the overall operation of the facility from which the discharge originates or having overall responsibility for environmental matters for the company, and the written authorization is submitted to the town.

(5) "Best Management Practices" or "BMPs" means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to implement the prohibitions listed in § 18-209. BMPs also include treatment requirement, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw materials storage.

(6) "Biochemical Oxygen Demand (BOD)." The quantity of oxygen utilized in the biochemical oxidation of organic matter under standard laboratory procedure for five (5) days at twenty degrees Celsius (20°C) expressed in terms of weight and concentration (milligrams per liter (mg/l)).

(7) "Building sewer." A sewer conveying wastewater from the premises of a user to the publicly owned sewer collection system.

(8) "Categorical standards." The National Categorical Pretreatment Standards as found in 40 CFR chapter I, subchapter N, parts 405-471.

(9) "town." The Board of Mayor and Aldermen, Town of _____, Tennessee.

(10) "Commissioner." The commissioner of environment and conservation or the commissioner's duly authorized representative and, in the event of the commissioner's absence or a vacancy in the office of commissioner, the deputy commissioner.

(11) "Compatible pollutant." Shall mean BOD, suspended solids, pH, fecal coliform bacteria, and such additional pollutants as are now or may in the future be specified and controlled in the city's/town's NPDES permit for its wastewater treatment works where sewer works have been designed and used to reduce or remove such pollutants.

(12) "Composite sample." A sample composed of two (2) or more discrete samples. The aggregate sample will reflect the average water quality covering the compositing or sample period.

(13) "Control authority." The term "control authority" shall refer to the "approval authority," defined herein above; or the local hearing authority if the town has an approved pretreatment program under the provisions of 40 CFR 403.11.

(14) "Cooling water." The water discharge from any use such as air conditioning, cooling, or refrigeration, or to which the only pollutant added is heat.

(15) "Customer." Any individual, partnership, corporation, association, or group who receives sewer service from the town under either an express or implied contract requiring payment to the town for such service.

(16) "Daily maximum." The arithmetic average of all effluent samples for a pollutant (except pH) collected during a calendar day. The daily maximum for pH is the highest value tested during a twenty-four (24) hour calendar day.

(17) "Daily maximum limit." The maximum allowable discharge limit of a pollutant during a calendar day. Where the limit is expressed in units of mass, the limit is the maximum amount of total mass of the pollutant that can be discharged during the calendar day. Where the limit is expressed in concentration, it is the arithmetic average of all concentration measurements taken during the calendar day.

(18) "Direct discharge." The discharge of treated or untreated wastewater directly to the waters of the State of Tennessee.

(19) "Domestic wastewater." Wastewater that is generated by a single family, apartment or other dwelling unit or dwelling unit equivalent or commercial establishment containing sanitary facilities for the disposal of wastewater and used for residential or commercial purposes only.

(20) "Environmental Protection Agency, or EPA." The U.S. Environmental Protection Agency, or where appropriate, the term may also be used as a designation for the administrator or other duly authorized official of the said agency.

(21) "Garbage." Solid wastes generated from any domestic, commercial or industrial source.

(22) "Grab sample." A sample which is taken from a waste stream on a one time basis with no regard to the flow in the waste stream and is collected over a period of time not to exceed fifteen (15) minutes. Grab sampling procedure: Where composite sampling is not an appropriate sampling technique, a grab sample(s) shall be taken to obtain influent and effluent operational data. Collection of influent grab samples should precede collection of effluent samples by approximately one (1) detention period. The detention period is to be based on a twenty-four (24) hour average daily flow value. The average daily flow used will be based upon the average of the daily flows during the same month of the previous year. Grab samples will be required, for example, where the parameters being evaluated are those, such as cyanide and phenol, which may not be held for any extended period because of biological, chemical or physical interactions which take place after sample collection and affect the results.

(23) "Grease interceptor." An interceptor whose rated flow is fifty (50) g.p.m. (gallons per minute) or less and is generally located inside the building.

(24) "Grease trap." An interceptor whose rated flow is fifty (50) g.p.m. or more and is located outside the building.

(25) "Holding tank waste." Any waste from holding tanks such as vessels, chemical toilets, campers, trailers, septic tanks, and vacuum pump tank trucks.

(26) "Incompatible pollutant." Any pollutant which is not a "compatible pollutant" as defined in this section.

(27) "Indirect discharge." The introduction of pollutants into the WWF from any non-domestic source.

(28) "Industrial user." A source of indirect discharge which does not constitute a "discharge of pollutants" under regulations issued pursuant to section 402, of the Act (33 U.S.C. §1342).

(29) "Industrial wastes." Any liquid, solid, or gaseous substance, or combination thereof, or form of energy including heat, resulting from any process of industry, manufacture, trade, food processing or preparation, or business or from the development of any natural resource.

(30) "Instantaneous limit." The maximum concentration of a pollutant allowed to be discharged at any time, determined from the analysis of any discrete or composited sample collected, independent of the industrial flow rate and the duration of the sampling event.

(31) "Interceptor." A device designed and installed to separate and retain for removal, by automatic or manual means, deleterious, hazardous or undesirable matter from normal wastes, while permitting normal sewage or waste to discharge into the drainage system by gravity.

(32) "Interference." A discharge that, alone or in conjunction with a discharge or discharges from other sources, inhibits or disrupts the WWF, its treatment processes or operations, or its sludge processes, use or disposal, or exceeds the design capacity of the treatment works or collection system.

(33) "Local administrative officer." The chief administrative officer of the local hearing authority.

(34) "Local hearing authority." The board of mayor and aldermen or such person or persons appointed by the board to administer and enforce the provisions of this chapter and conduct hearings pursuant to section 205.

(35) "National categorical pretreatment standard" Any regulation containing pollutant discharge limits promulgated by the EPA in accordance with section 307(b) and (c) of the Act (33 U.S.C. § 1347) which applies to a specific category of industrial users.

(36) "NAICS, North American Industrial Classification System." A system of industrial classification jointly agreed upon by Canada, Mexico and the United States. It replaces the Standard Industrial Classification (SIC) system.

(37) "New source." (a) Any building, structure, facility or installation from which there is or may be a discharge of pollutants, the construction of which commenced after the publication of proposed pretreatment

standards under section 307(c) of the Clean Water Act which will be applicable to such source if such Standards are thereafter promulgated in accordance with that section, provided that:

(i) The building structure, facility or installation is constructed at a site at which no other source is located; or

(ii) The building, structure, facility or installation totally replaces the process or production equipment that causes the discharge of pollutants at an existing source; or

(iii) The production or wastewater generating processes of the building, structure, facility or installation are substantially independent of an existing source at the same site. In determining whether these are substantially independent, factors such as the extent to which the new facility is engaged in the same general type of activity as the existing source should be considered.

(b) Construction on a site at which an existing source is located results in a modification rather than a new source if the construction does not create a new building, structure, facility, or installation meeting the criteria of parts (a)(ii) or (a)(iii) of this definition but otherwise alters, replaces, or adds to existing process or production equipment.

(c) Construction of a new source as defined under this paragraph has commenced if the owner or operator has:

(i) Begun, or caused to begin as part of a continuous onsite construction program:

(A) Any placement, assembly, or installation of facilities or equipment; or

(B) Significant site preparation work including cleaning, excavation or removal of existing buildings, structures, or facilities which is necessary for the placement, assembly, or installation of new source facilities or equipment; or

(ii) Entered into a binding contractual obligation for the purchase of facilities or equipment which are intended to be used in its operation within a reasonable time. Options to purchase or contracts which can be terminated or modified without substantial loss, and contracts for feasibility, engineering, and design studies do not constitute a contractual obligation under this paragraph

(38) "NPDES (National Pollution Discharge Elimination System)." The program for issuing, conditioning, and denying permits for the discharge of pollutants from point sources into navigable waters, the contiguous zone, and the oceans pursuant to section 402 of the Clean Water Act as amended.

(39) "Pass-through." A discharge which exits the Wastewater Facility (WWF) into waters of the state in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of

a violation of any requirement of the WWF's NPDES permit including an increase in the magnitude or duration of a violation.

(40) "Person." Any individual, partnership, co partnership, firm, company, corporation, association, joint stock company, trust, estate, governmental entity or any other legal entity, or their legal representatives, agents, or assigns. The masculine gender shall include the feminine and the singular shall include the plural where indicated by the context.

(41) "pH." The logarithm (base 10) of the reciprocal of the concentration of hydrogen ions expressed in grams per liter of solution.

(42) "Pollution." The man made or man induced alteration of the chemical, physical, biological, and radiological integrity of water.

(43) "Pollutant." Any dredged spoil, solid waste, incinerator residue, filter backwash, sewage, garbage, sewage sludge, munitions, medical waste, chemical wastes, biological materials, radioactive materials, heat, wrecked or discharged equipment, rock, sand, cellar dirt, and industrial, municipal, and agricultural waste and certain characteristics of wastewater (e.g., pH, temperature, turbidity, color, BOD, COD, toxicity, or odor discharge into water).

(44) "Pretreatment or treatment." The reduction of the amount of pollutants, the elimination of pollutants, or the alteration of the nature of pollutant properties in wastewater to a less harmful state prior to or in lieu of discharging or otherwise introducing such pollutants into a POTW. The reduction or alteration can be obtained by physical, chemical, biological processes, or process changes or other means, except through dilution as prohibited by 40 CFR section 403.6(d).

(45) "Pretreatment coordinator." The person designated by the local administrative officer or his authorized representative to supervise the operation of the pretreatment program.

(46) "Pretreatment requirements." Any substantive or procedural requirement related to pretreatment other than a national pretreatment standard imposed on an industrial user.

(47) "Pretreatment standards or standards." A prohibited discharge standard, categorical pretreatment standard and local limit.

(48) "Publicly Owned Treatment Works (POTW)." A treatment works as defined by section 212 of the Act, (33 U.S.C. § 1292) which is owned in this instance by the municipality (as defined by section 502(4) of the Act). This definition includes any devices and systems used in the storage, treatment, recycling and reclamation of municipal sewage or industrial wastes of a liquid nature. It also includes sewers, pipes and other conveyances only if they convey wastewater to a POTW treatment plant. The term also means the municipality as defined in section 502(4) of the Act, which has jurisdiction over the indirect discharges to and the discharges from such a treatment works. See WWF, Wastewater Facility, found in definition number (63), below.

(49) "Shall" is mandatory; "may" is permissive.

(50) "Significant industrial user." The term significant industrial user means:

(a) All industrial users subject to categorical pretreatment standards under 40 CFR 403.6 and 40 CFR chapter I, subchapter N; or

(b) Any other industrial user that: discharges an average of twenty five thousand (25,000) gallons per day or more of process wastewater to the WWF (excluding sanitary, non-contact cooling and boiler blowdown wastewater); contributes a process wastestream which makes up five percent (5%) or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant; or is designated as such by the control authority as defined in 40 CFR 403.12(a) on the basis that the industrial user has a reasonable potential for adversely affecting the WWF's operation or for violating any pretreatment standard or requirement (in accordance with 40 CFR 403.8(f)(6)).

(51) "Significant noncompliance." Per 1200-4-14-.08(6)(b)8.

(a) Chronic violations of wastewater discharge limits, defined here as those in which sixty-six percent (66%) or more of all of the measurements taken for each parameter taken during a six (6) month period exceed (by any magnitude) a numeric pretreatment standard or requirement, including instantaneous limit.

(b) Technical Review Criteria (TRC) violations, defined here as those in which thirty-three percent or more of all of the measurements for each pollutant parameter taken during a six (6) month period equal or exceed the product of the numeric pretreatment standard or requirement, including instantaneous limits multiplied by the applicable TRC (TRC=1.4 for BOD, TSS, fats, oils and grease, and 1.2 for all other pollutants except pH). TRC calculations for pH are not required.

(c) Any other violation of a pretreatment standard or requirement (daily maximum or longer-term average, instantaneous limit, or narrative standard) that the WWF determines has caused, alone or in combination with other discharges, interference or pass through (including endangering the health of WWF personnel or the general public).

(d) Any discharge of a pollutant that has caused imminent endangerment to human health, welfare or to the environment or has resulted in the WWF's exercise of its emergency authority under § 18-205(1)(b)(i)(D), emergency order, to halt or prevent such a discharge.

(e) Failure to meet, within 90 days after the schedule date, a compliance schedule milestone contained in a local control mechanism or enforcement order for starting construction, completing construction, or attaining final compliance.

(f) Failure to provide, within forty-five (45) days after their due date, required reports such as baseline monitoring reports, ninety (90)

day compliance reports, periodic self-monitoring reports, and reports on compliance with compliance schedules.

(g) Failure to accurately report noncompliance.

(h) Any other violation or group of violations, which may include a violation of best management practices, which the WWF determines will adversely affect the operation or implementation of the local pretreatment program.

(i) Continuously monitored pH violations that exceed limits for a time period greater than fifty (50) minutes or exceed limits by more than 0.5 s.u. more than eight times in four hours.

(52) "Slug." Any discharge of a non-routine, episodic nature, including but not limited to an accidental spill or a non-customary batch discharge, which has a reasonable potential to cause interference or pass-through, or in any other way violate the WWF's regulations, local limits, or permit conditions.

(53) "Standard Industrial Classification (SIC)." A classification pursuant to the Standard Industrial Classification Manual issued by the Executive Office of the President, Office of Management and Budget, 1972.

(54) "State." The State of Tennessee.

(55) "Storm sewer or storm drain." A pipe or conduit which carries storm and surface waters and drainage, but excludes sewage and industrial wastes. It may, however, carry cooling waters and unpolluted waters, upon approval of the superintendent.

(56) "Stormwater." Any flow occurring during or following any form of natural precipitation and resulting therefrom.

(57) "Superintendent." The local administrative officer or person designated by him to supervise the operation of the publicly owned treatment works and who is charged with certain duties and responsibilities by this chapter, or his duly authorized representative.

(58) "Surcharge." An additional fee assessed to a user who discharges compatible pollutants at concentrations above the established surcharge limits. Surcharge limits are the level at which the permit holder will be billed higher rates to offset the cost of treating wastewater which exceeds the surcharge limits. Exceeding a surcharge limit but not a monthly average or daily maximum limit will not result in enforcement action.

(59) "Suspended solids." The total suspended matter that floats on the surface of, or is suspended in, water, wastewater, or other liquids and that is removable by laboratory filtering.

(60) "Toxic pollutant." Any pollutant or combination of pollutants listed as toxic in regulations published by the Administrator of the Environmental Protection Agency under the provision of CWA 307(a) or other Acts.

(61) "Twenty-four (24) hour flow proportional composite sample." A sample consisting of several sample portions collected during a twenty-four (24) hour period in which the portions of a sample are proportioned to the flow and combined to form a representative sample.

(62) "User." The owner, tenant or occupant of any lot or parcel of land connected to a sanitary sewer, or for which a sanitary sewer line is available if a municipality levies a sewer charge on the basis of such availability, *Tennessee Code Annotated*, § 68-221-201.

(63) "Wastewater." The liquid and water carried industrial or domestic wastes from dwellings, commercial buildings, industrial facilities, and institutions, whether treated or untreated, which is contributed into or permitted to enter the WWF.

(64) "Wastewater facility" Any or all of the following: the collection/transmission system, treatment plant, and the reuse or disposal system, which is owned by any person. This definition includes any devices and systems used in the storage, treatment, recycling and reclamation of municipal sewage or industrial waste of a liquid nature. It also includes sewers, pipes and other conveyances only if they convey wastewater to a WWF treatment plant. The term also means the municipality as defined in section 502(4) of the Federal Clean Water Act, which has jurisdiction over the indirect discharges to and the discharges from such a treatment works. WWF was formally known as a POTW, or Publicly Owned Treatment Works.

(65) "Waters of the state." All streams, lakes, ponds, marshes, watercourses, waterways, wells, springs, reservoirs, aquifers, irrigation systems, drainage systems, and other bodies of accumulation of water, surface or underground, natural or artificial, public or private, that are contained within, flow through, or border upon the state or any portion thereof.

(66) "1200-4-14." Chapter 1200-4-14 of the Rules and Regulations of the State of Tennessee, Pretreatment Requirements.

18-204. Proper waste disposal required. (1) It shall be unlawful for any person to place, deposit, or permit to be deposited in any unsanitary manner on public or private property within the service area of the town, any human or animal excrement, garbage, or other objectionable waste.

(2) It shall be unlawful to discharge to any waters of the state within the service area of the town any sewage or other polluted waters, except where suitable treatment has been provided in accordance with provisions of this ordinance or town or state regulations.

(3) Except as herein provided, it shall be unlawful to construct or maintain any privy, privy vault, cesspool, or other facility intended or used for the disposal of sewage.

(4) Except as provided in (6) below, the owner of all houses, buildings, or properties used for human occupancy, employment, recreation, or other purposes situated within the service area in which there is now located or may in the future be located a public sanitary sewer, is hereby required at his expense to install suitable toilet facilities therein, and to connect such facilities directly with the proper private or public sewer in accordance with the provisions of this chapter. Where public sewer is available property owners shall

within sixty (60) days after date of official notice to do so, connect to the public sewer. Service is considered "available" when a public sewer main is located in an easement, right-of-way, road or public access way which abuts the property.

(5) Discharging into the sanitary sewer without permission of the town is strictly prohibited and is deemed "theft of service."

(6) Where a public sanitary sewer is not available under the provisions of (4) above, the building sewer shall be connected to a private sewage disposal system complying with the provisions of § 18-205.

(7) The owner of a manufacturing facility may discharge wastewater to the waters of the state provided that he obtains an NPDES permit and meets all requirements of the Federal Clean Water Act, the NPDES permit, and any other applicable local, state, or federal statutes and regulations.

(8) Users have a duty to comply with the provisions of this ordinance in order for the town to fulfill the stated policy and purpose. Significant Industrial users must comply with the provisions of this ordinance and applicable state and federal rules according to the nature of the industrial discharge.

18-205. Private domestic wastewater disposal. (1) Availability.

(a) Where a public sanitary sewer is not available under the provisions of § 18-204(4), the building sewer shall be connected, until the public sewer is available, to a private wastewater disposal system complying with the provisions of the applicable local and state regulations.

(b) The owner shall operate and maintain the private sewage disposal facilities in a sanitary manner at all times, at no expense to the town. When it becomes necessary to clean septic tanks, the sludge may be disposed of only according to applicable federal and state regulations.

(c) Where a public sewer becomes available, the building sewer shall be connected to said sewer within sixty (60) days after date of official notice from the town to do so.

(2) **Requirements.** (a) The type, capacity, location and layout of a private sewerage disposal system shall comply with all local or state regulations. Before commencement of construction of a private sewerage disposal system, the owner shall first obtain a written approval from the county health department. The application for such approval shall be made on a form furnished by the county health department which the applicant shall supplement with any plans or specifications that the department has requested.

(b) Approval for a private sewerage disposal system shall not become effective until the installation is completed to the satisfaction of the local and state authorities, who shall be allowed to inspect the work at any stage of construction.

(c) The type, capacity, location, and layout of a private sewage disposal system shall comply with all recommendations of the Tennessee Department of Environment and Conservation, and the county health department. No septic tank or cesspool shall be permitted to discharge to waters of Tennessee.

(d) No statement contained in this chapter shall be construed to interfere with any additional or future requirements that may be imposed by the town and the county health department.

18-206. Connection to public sewers. (1) Application for service.

(a) There shall be two (2) classifications of service:

(i) Residential; and

(ii) Service to commercial, industrial and other nonresidential establishments.

In either case, the owner or his agent shall make application for connection on a special form furnished by the town. Applicants for service to commercial and industrial establishments shall be required to furnish information about all waste producing activities, wastewater characteristics and constituents. The application shall be supplemented by any plans, specifications or other information considered pertinent in the judgment of the superintendent. Details regarding commercial and industrial permits include but are not limited to those required by this ordinance. Service connection fees for establishing new sewer service are paid to the town. Industrial user discharge permit fees may also apply. The receipt by the town of a prospective customer's application for connection shall not obligate the town to render the connection. If the service applied for cannot be supplied in accordance with this chapter and the city's/town's rules and regulations and general practice, or state and federal requirement, the connection charge will be refunded in full, and there shall be no liability of the town to the applicant for such service.

(b) Users shall notify the town of any proposed new introduction of wastewater constituents or any proposed change in the volume or character of the wastewater being discharged to the system a minimum of sixty (60) days prior to the change. The town may deny or limit this new introduction or change based upon the information submitted in the notification.

(2) Prohibited connections. No person shall make connections of roof downspouts, sump pumps, basement wall seepage or floor seepage, exterior foundation drains, area way drains, or other sources of surface runoff or groundwater to a building sewer or building drain which in turn is connected directly or indirectly to a public sanitary sewer. Any such connections which already exist on the effective date of this ordinance shall be completely and permanently disconnected within sixty (60) days of the effective day of this ordinance. The owners of any building sewer having such connections, leaks or

defects shall bear all of the costs incidental to removal of such sources. Pipes, sumps and pumps for such sources of ground water shall be separate from the sanitary sewer.

(3) Physical connection to public sewer. (a) No person shall uncover, make any connections with or opening into, use, alter, or disturb any public sewer or appurtenance thereof. The town shall make all connections to the public sewer upon the property owner first submitting a connection application to the town.

The connection application shall be supplemented by any plans, specifications or other information considered pertinent in the judgment of the superintendent. A service connection fee shall be paid to the town at the time the application is filed.

The applicant is responsible for excavation and installation of the building sewer which is located on private property. The town will inspect the installation prior to backfilling and make the connection to the public sewer.

(b) All costs and expenses incident to the installation, connection, and inspection of the building sewer shall be borne by the owner including all service and connection fees. The owner shall indemnify the town from any loss or damage that may directly or indirectly be occasioned by the installation of the building sewer.

(c) A separate and independent building sewer shall be provided for every building; except where one building stands at the rear of another on an interior lot and no private sewer is available or can be constructed to the rear building through an adjoining alley, courtyard, or driveway, the building sewer from the front building may be extended to the rear building and the whole considered as one building sewer. Where property is subdivided and buildings use a common building sewer are now located on separate properties, the building sewers must be separated within sixty (60) days.

(d) Old building sewers may be used in connection with new buildings only when they are found, on examination and tested by the superintendent to meet all requirements of this chapter. All others may be sealed to the specifications of the superintendent.

(e) Building sewers shall conform to the following requirements:

(i) The minimum size of a building sewer shall be as follows: Conventional sewer system four inches (4").

(ii) The minimum depth of a building sewer shall be eighteen inches (18").

(iii) Building sewers shall be laid on the following grades: four inch (4") sewers - one-eighth inch (1/8") per foot.

Larger building sewers shall be laid on a grade that will produce a velocity when flowing full of at least two feet (2') feet per second.

(iv) Building sewers shall be installed in uniform alignment at uniform slopes.

(v) Building sewers shall be constructed only of polyvinyl chloride pipe Schedule 40 or better. Joints shall be solvent welded or compression gaskets designed for the type of pipe used. No other joints shall be acceptable.

(vi) Cleanouts shall be provided to allow cleaning in the direction of flow. A cleanout shall be located five feet (5') outside of the building, as it crosses the property line and one at each change of direction of the building sewer which is greater than forty-five degrees (45°) degrees. Additional cleanouts shall be placed not more than seventy-five feet (75') apart in horizontal building sewers of six inch (6") nominal diameter and not more than one hundred feet (100') apart for larger pipes. Cleanouts shall be extended to or above the finished grade level directly above the place where the cleanout is installed and protected from damage. A "Y" (wye) and 1/8 bend shall be used for the cleanout base. Cleanouts shall not be smaller than four inches (4"). Blockages on the property owner's side of the property line cleanout are the responsibility of the property owner.

(vii) Connections of building sewers to the public sewer system shall be made only by the town and shall be made at the appropriate existing wyes or tee branch using compression type couplings or collar type rubber joint with stainless steel bands. Where existing wye or tee branches are not available, connections of building services shall be made by either removing a length of pipe and replacing it with a wye or tee fitting using flexible neoprene adapters with stainless steel bands of a type approved by the superintendent. Bedding must support pipe to prevent damage or sagging. All such connections shall be made gastight and watertight.

(viii) In all buildings in which any building drain is too low to permit gravity flow to the public sewer, sanitary sewage carried by such building drain shall be lifted by an approved pump system according to § 18-207 and discharged to the building sewer at the expense of the owner.

(ix) The methods to be used in excavating, placing of pipe, jointing, testing, backfilling the trench, or other activities in the construction of a building sewer which have not been described above shall conform to the requirements of the building and plumbing code or other applicable rules and regulations of the town or to the procedures set forth in appropriate specifications by the ASTM. Any deviation from the prescribed procedures and

materials must be approved by the superintendent before installation.

(x) An installed building sewer shall be gastight and watertight.

(f) All excavations for building sewer installation shall be adequately guarded with barricades and lights so as to protect the public from hazard. Streets, sidewalks, parkways, and other public property disturbed in the course of the work shall be restored in a manner satisfactory to the town.

(g) No person shall make connection of roof downspouts, exterior foundation drains, areaway drains, basement drains, sump pumps, or other sources of surface runoff or groundwater to a building directly or indirectly to a public sanitary sewer.

(h) Inspection of connections.

(i) The sewer connection and all building sewers from the building to the public sewer main line shall be inspected before the underground portion is covered, by the superintendent or his authorized representative.

(ii) The applicant for discharge shall notify the superintendent when the building sewer is ready for inspection and connection to the public sewer. The connection shall be made under the supervision of the superintendent or his representative.

(4) Maintenance of building sewers. (a) Each individual property owner shall be entirely responsible for the construction, maintenance, repair or replacement of the building sewer as deemed necessary by the superintendent to meet specifications of the town. Owners failing to maintain or repair building sewers or who allow stormwater or ground water to enter the sanitary sewer may face enforcement action by the superintendent up to and including discontinuation of water and sewer service.

(b) The town may inspect the facilities of any user to ascertain whether the purpose of this chapter is being met and all requirements are being complied with.

(c) The point of division between the building sewer and the town owned sewer tap or service connection shall be at the property line, right-of-way line, property line sewer cleanout, or such point in this general area as identified by the superintendent. The town owned tap or service line connection cannot extend onto private property except that minimal distance to the edge of right-of-ways, easements, or that distance necessary to cross other town utility lines and provide a location unencumbered by other underground town utilities where the user can make a connection to the building sewer without risk of damage to those other town utilities.

(5) Sewer extensions. All expansion or extension of the public sewer constructed by property owners or developers must follow policies

and procedures developed by the town. In the absence of policies and procedures the expansion or extension of the public sewer must be approved in writing by the superintendent or manager of the wastewater collection system. All plans and construction must follow the latest edition of Tennessee Design Criteria for Sewerage Works, located at <http://www.state.tn.us/environment/wpc/publications/>. Contractors must provide the superintendent or manager with as-built drawing and documentation that all mandrel, pressure and vacuum tests as specified in design criteria were acceptable prior to use of the lines. Contractor's one (1) year warranty period begins with occupancy or first permanent use of the lines. Contractors are responsible for all maintenance and repairs during the warranty period and final inspections as specified by the superintendent or manager. The superintendent or manager must give written approval to the contractor to acknowledge transfer of ownership to the town. Failure to construct or repair lines to acceptable standards could result in denial or discontinuation of sewer service.

18-207. Septic tank effluent pump or grinder pump wastewater systems. When connection of building sewers to the public sewer by gravity flow lines is impossible due to elevation differences or other encumbrances, Septic Tank Effluent Pump (STEP) or Grinder Pump (GP) systems may be installed subject to the regulations of the town.

(1) Equipment requirements. (a) Septic tanks shall be of water tight construction and must be approved by the town.

(b) Pumps must be approved by the town and shall be maintained by the town.

(2) Installation requirements. Location of tanks, pumps, and effluent lines shall be subject to the approval of the town. Installation shall follow design criteria for STEP and GP systems as provided by the superintendent.

(3) Costs. STEP and GP equipment for new construction shall be purchased and installed at the developer's, homeowner's, or business owner's expense according to the specification of the town and connection will be made to the town sewer only after inspection and approval of the town.

(4) Ownership and easements. Homeowners or developers shall provide the town with ownership of the equipment and an easement for access to perform necessary maintenance or repair. Access by the town to the STEP and GP system must be guaranteed to operate, maintain, repair, restore service, and remove sludge. Access manholes, ports, and electrical disconnects must not be locked, obstructed or blocked by landscaping or construction.

(5) Use of STEP and GP systems. (a) Home or business owners shall follow the STEP and GP users guide provided by the superintendent.

(b) Home or business owners shall provide an electrical connection that meets specifications and shall provide electrical power.

(c) Home or business owners shall be responsible for maintenance of drain lines from the building to the STEP and GP tank.

(d) Prohibited uses of the STEP and GP system.

(i) Connection of roof guttering, sump pumps or surface drains.

(ii) Disposal of toxic household substances.

(iii) Use of garbage grinders or disposers.

(iv) Discharge of pet hair, lint, or home vacuum water.

(v) Discharge of fats, grease, and oil.

(6) Tank cleaning. Solids removal from the septic tank shall be the responsibility of the town. However, pumping required more frequently than once every five years shall be billed to the homeowner.

(7) Additional charges. The town shall be responsible for maintenance of the STEP and GP equipment. Repeat service calls for similar problems shall be billed to the homeowner or business at a rate of no more than the actual cost of the service call including but not limited to transportation, labor, materials, excavation, subcontractors, engineering fees, cleanup expenses, and other expenses related to the service call. In addition if the town receives regulatory fines related to equipment failure and sewage overflows all such fines will be passed on to the user.

18-208. Regulation of holding tank waste disposal or trucked in waste. (1) No person, firm, association or corporation shall haul in or truck in to the WWF any type of domestic, commercial or industrial waste unless such person, firm, association, or corporation obtains a written approval from the town to perform such acts or services.

Any person, firm, association, or corporation desiring a permit to perform such services shall file an application on the prescribed form. Upon any such application, said permit shall be issued by the superintendent when the conditions of this chapter have been met and providing the superintendent is satisfied the applicant has adequate and proper equipment to perform the services contemplated in a safe and competent manner.

(2) Fees. For each permit issued under the provisions of this chapter the applicant shall agree in writing by the provisions of this section and pay an annual service charge to the town to be set as specified in § 18-207 of this ordinance. Any such permit granted shall be for a specified period of time, and shall continue in full force and effect from the time issued until the expiration date, unless sooner revoked, and shall be nontransferable. The number of the permit granted hereunder shall be plainly painted in three inch (3") permanent letters on each side of each motor vehicle used in the conduct of the business permitted hereunder.

(3) Designated disposal locations. The superintendent shall designate approved locations for the emptying and cleansing of all equipment used in the performance of the services rendered under the permit herein provided for, and

it shall be a violation hereof for any person, firm, association or corporation to empty or clean such equipment at any place other than a place so designated. The superintendent may refuse to accept any truckload of waste at his discretion where it appears that the waste could interfere with the operation of the WWF.

(4) Revocation of permit. Failure to comply with all the provisions of the permit or this chapter shall be sufficient cause for the revocation of such permit by the superintendent. The possession within the service area by any person of any motor vehicle equipped with a body type and accessories of a nature and design capable of serving a septic tank of wastewater or excreta disposal system cleaning unit shall be prima facie evidence that such person is engaged in the business of cleaning, draining, or flushing septic tanks or other wastewater or excreta disposal systems within the service area of the Town of _____.

(5) Trucked in waste. This part includes waste from trucks, railcars, barges, etc., or temporally pumped waste, all of which are prohibited without a permit issued by the superintendent. This approval may require testing, flow monitoring and record keeping.

18-209. Discharge regulations. (1) General discharge prohibitions. No user shall contribute or cause to be contributed, directly or indirectly, any pollutant or wastewater which will pass through or interfere with the operation and performance of the WWF. These general prohibitions apply to all such users of a WWF whether or not the user is subject to national categorical pretreatment standards or any other national, state, or local pretreatment standards or requirements. Violations of these general and specific prohibitions or the provisions of this section or other pretreatment standard may result in the issuance of an industrial pretreatment permit, surcharges, discontinuance of water and/or sewer service and other fines and provisions of §§ 18-210 and 18-205. A user may not contribute the following substances to any WWF:

(a) Any liquids, solids, or gases which by reason of their nature or quantity are, or may be, sufficient either alone or by interaction with other substances to cause fire or explosion or be injurious in any other way to the WWF or to the operation of the WWF. Prohibited flammable materials including, but not limited to, wastestreams with a closed cup flash point of less than one hundred forty degrees Fahrenheit (140° F) or sixty degrees Celsius (60° C) using the test methods specified in 40 CFR 261.21. Prohibited materials include, but are not limited to, gasoline, kerosene, naphtha, benzene, toluene, xylene, ethers, alcohols, ketones, aldehydes, peroxides, chlorates, perchlorates, bromate, carbides, hydrides and sulfides and other flammable substances.

(b) Any wastewater having a pH less than 5.5 or higher than 9.5 or wastewater having any other corrosive property capable of causing

damage or hazard to structures, equipment, and/or personnel of the WWF.

(c) Solid or viscous substances which may cause obstruction to the flow in a sewer or other interference with the operation of the wastewater treatment facilities including, but not limited to: grease, garbage with particles greater than one half inch (1/2") in any dimension, waste from animal slaughter, ashes, cinders, sand, spent lime, stone or marble dust, metal, glass, straw, shavings, grass clippings, rags, spent grains, spent hops, waste paper, wood, plastics, mud, or glass grinding or polishing wastes.

(d) Any pollutants, including oxygen demanding pollutants (BOD, etc.) released at a flow rate and/or pollutant concentration which will cause interference to the WWF.

(e) Any wastewater having a temperature which will inhibit biological activity in the WWF treatment plant resulting in interference, but in no case wastewater with a temperature at the introduction into the WWF which exceeds forty degrees Celsius (40° C (one hundred four degrees Fahrenheit (104° F)) unless approved by the State of Tennessee.

(f) Petroleum oil, nonbiodegradable cutting oil, or products of mineral oil origin in amounts that will cause interference or pass through.

(g) Pollutants which result in the presence of toxic gases, vapors, or fumes within the WWF in a quantity that may cause acute worker health and safety problems.

(h) Any wastewater containing any toxic pollutants, chemical elements, or compounds in sufficient quantity, either singly or by interaction with other pollutants, to injure or interfere with any wastewater treatment process, constitute a hazard to humans, including wastewater plant and collection system operators, or animals, create a toxic effect in the receiving waters of the WWF, or to exceed the limitation set forth in a categorical pretreatment standard. A toxic pollutant shall include but not be limited to any pollutant identified pursuant to section 307(a) of the Act.

(i) Any trucked or hauled pollutants except at discharge points designated by the WWF.

(j) Any substance which may cause the WWF's effluent or any other product of the WWF such as residues, sludges, or scums, to be unsuitable for reclamation and reuse or to interfere with the reclamation process. In no case, shall a substance discharged to the WWF cause the WWF to be in non compliance with sludge use or disposal criteria, 40 CFR 503, guidelines, or regulations developed under section 405 of the Act; any criteria, guidelines, or regulations affecting sludge use or disposal developed pursuant to the Solid Waste Disposal Act, the Clean

Air Act, the Toxic Substances Control Act, or state criteria applicable to the sludge management method being used.

(k) Any substances which will cause the WWF to violate its NPDES permit or the receiving water quality standards.

(l) Any wastewater causing discoloration of the wastewater treatment plant effluent to the extent that the receiving stream water quality requirements would be violated, such as, but not limited to, dye wastes and vegetable tanning solutions.

(m) Any waters or wastes causing an unusual volume of flow or concentration of waste constituting "slug" as defined herein.

(n) Any waters containing any radioactive wastes or isotopes of such halflife or concentration as may exceed limits established by the superintendent in compliance with applicable state or federal regulations.

(o) Any wastewater which causes a hazard to human life or creates a public nuisance.

(p) Any waters or wastes containing animal or vegetable fats, wax, grease, or oil, whether emulsified or not, which cause accumulations of solidified fat in pipes, lift stations and pumping equipment, or interfere at the treatment plant.

(q) Detergents, surfactants, surface-acting agents or other substances which may cause excessive foaming at the WWF or pass through of foam.

(r) Wastewater causing, alone or in conjunction with other sources, the WWF to fail toxicity tests.

(s) Any stormwater, surface water, groundwater, roof runoff, subsurface drainage, uncontaminated cooling water, or unpolluted industrial process waters to any sanitary sewer. Stormwater and all other unpolluted drainage shall be discharged to such sewers as are specifically designated as storm sewers, or to a natural outlet approved by the superintendent and the Tennessee Department of Environment and Conservation. Industrial cooling water or unpolluted process waters may be discharged on approval of the superintendent and the Tennessee Department of Environment and Conservation, to a storm sewer or natural outlet.

CHAPTER 3

CROSS-CONNECTIONS, AUXILIARY INTAKES, ETC.¹

SECTION

- 18-301. Definitions.
- 18-302. Standards.
- 18-303. Construction, operation, and supervision.
- 18-304. Statement required.
- 18-305. Inspections required.
- 18-306. Right of entry for inspections.
- 18-307. Correction of existing violations.
- 18-308. Use of protective devices.
- 18-309. Unpotable water to be labeled.
- 18-310. Violations and penalty.

18-301. Definitions. The following definitions and terms shall apply in the interpretation and enforcement of this chapter:

- (1) "Auxiliary intake." Any piping connection or other device whereby water may be secured from a source other than that normally used.
- (2) "Bypass." Any system of piping or other arrangement whereby the water may be diverted around any part or portion of a water purification plant.
- (3) "Cross-connection." Any physical arrangement whereby the public water supply is connected, directly or indirectly, with any other water supply system, whether sewer, drain, conduit, pool, storage reservoir, plumbing fixture, or other device which contains, or may contain, contaminated water, sewage, or other waste or liquid of unknown or unsafe quality which may be capable of imparting contamination to the public water supply as a result of backflow. Bypass arrangements, jumper connections, removable sections, swivel or change-over devices through which, or because of which, backflow could occur are considered to be cross-connections;
- (4) "Interconnection." Any system of piping or other arrangement whereby the public water supply is connected directly with a sewer, drain, conduit, pool, storage reservoir, or other device which does or may contain sewage or other waste or liquid which would be capable of imparting contamination to the public water supply.
- (5) "Person." Any and all persons, natural or artificial, including any individual, firm, or association, and any municipal or private corporation organized or existing under the laws of this or any other state or country.

¹Municipal code reference

Plumbing and related codes: title 12.

(6) "Public water supply." The waterworks system furnishing water to the town for general use and which supply is recognized as the public water supply by the Tennessee Department of Environment and Conservation.

18-302. Standards. The municipal public water supply is to comply with *Tennessee Code Annotated*, §§ 68-221-701 to 68-221-719 as well as the Rules and Regulations for Public Water Supplies, legally adopted in accordance with this code, which pertain to cross-connections, auxiliary intakes, bypasses, and interconnections, and establish an effective ongoing program to control these undesirable water uses.

18-303. Construction, operation, and supervision. It shall be unlawful for any person to cause a cross-connection to be made, or allow one to exist for any purpose whatsoever, unless the construction and operation of same have been approved by the Tennessee Department of Environment and Conservation and the operation of such cross connection, auxiliary intake, bypass or interconnection is at all times under the direct supervision of the water supervisor or his representative.

18-304. Statement required. Any person whose premises are supplied with water from the public water supply and who also has on the same premises a separate source of water supply, or stores water in an uncovered or unsanitary storage reservoir from which the water stored therein is circulated through a piping system, shall file with the water department a statement of the non-existence of unapproved or unauthorized cross-connections, auxiliary intakes, bypasses, or interconnections. Such statement shall also contain an agreement that no cross connection, auxiliary intake, bypass, or interconnection will be permitted upon the premises.

18-305. Inspections required. It shall be the duty of the water supervisor to cause inspections to be made of all properties served by the public water supply where cross-connections with the public water supply are deemed possible. The frequency of inspections and reinspection, based on potential health hazards involved, shall be established by the water supervisor and as approved by the Tennessee Department of Environment and Conservation.

18-306. Right of entry for inspections. The water supervisor or his authorized representative shall have the right to enter, at any reasonable time, any property served by a connection to the public water supply for the purpose of inspecting the piping system or systems therein for cross-connections, auxiliary intakes, bypasses, or interconnections. On request, the owner, lessee, or occupant of any property so served shall furnish to the inspection agency any pertinent information regarding the piping system or systems on such property.

The refusal of such information or refusal of access, when requested, shall be deemed evidence of the presence of cross-connections.

18-307. Correction of existing violations. Any person who now has cross-connections, auxiliary intakes, bypasses, or interconnections in violation of the provisions of this chapter shall be allowed a reasonable time within which to comply with the provisions of this chapter. After a thorough investigation of existing conditions and an appraisal of the time required to complete the work, the amount of time shall be designated by the water supervisor.

The failure to correct conditions threatening the safety of the public water system as prohibited by this chapter and the *Tennessee Code Annotated*, § 68-221-711, within a reasonable time and within the time limits set by the water supervisor shall be grounds for denial of water service. If proper protection has not been provided after a reasonable time, the water supervisor shall give the customer legal notification that water service is to be discontinued and shall physically separate the public water supply from the customer's on-site piping system in such a manner that the two systems cannot again be connected by an unauthorized person.

Where cross-connections, interconnections, auxiliary intakes, or bypasses are found that constitute an extreme hazard of immediate concern of contaminating the public water system, the management of the water supply shall require that immediate corrective action be taken to eliminate the threat to the public water system. Immediate steps shall be taken to disconnect the public water supply from the on-site piping system unless the imminent hazard(s) is (are) corrected immediately.

18-308. Use of protective devices. Where the nature of use of the water supplied a premises by the water department is such that it is deemed

(1) Impractical to provide an effective air-gap separation,
(2) That the owner and/or occupant of the premises cannot, or is not willing, to demonstrate to the water supervisor, or his designated representative, that the water use and protective features of the plumbing are such as to propose no threat to the safety or potability of the water supply,

(3) That the nature and mode of operation within a premises are such that frequent alterations are made to the plumbing,

(4) There is a likelihood that protective measures may be subverted, altered, or disconnected, the water supervisor or his designated representative, shall require the use of an approved protective device on the service line serving the premises to assure that any contamination that may originate in the customer's premises is contained therein. The protective device shall be a reduced pressure zone type backflow preventer approved by the Tennessee Department of Environment and Conservation as to manufacture, model, and size. The method of installation of backflow protective devices shall be approved by the water department prior to installation and shall comply with the criteria

set forth by the Tennessee Department of Environment and Conservation. The installation shall be at the expense of the owner or occupant of the premises.

Personnel of the municipal public water supply shall have the right to inspect and test the device or devices on an annual basis or whenever deemed necessary by the water supervisor or his designated representative. Water service shall not be disrupted to test the device without the knowledge of the occupant of the premises.

Where the use of water is critical to the continuance of normal operations or protection of life, property, or equipment, duplicate units shall be provided to avoid the necessity of discontinuing water service to test or repair the protective device or devices. Where it is found that only one unit has been installed and the continuance of service is critical, the water supervisor shall notify, in writing, the occupant of the premises of plans to discontinue water service and arrange for a mutually acceptable time to test and/or repair the device. The water supervisor shall require the occupant of the premises to make all repairs indicated promptly, to keep the unit(s) working properly, and the expense of such repairs shall be borne by the owner or occupant of the premises. Repairs shall be made by qualified personnel acceptable to the water supervisor.

The failure to maintain backflow prevention devices in proper working order shall be grounds for discontinuing water service to a premises. Likewise, the removal, bypassing, or altering of the protective devices or the installation thereof so as to render the devices ineffective shall constitute grounds for discontinuance of water service. Water service to such premises shall not be restored until the customer has corrected or eliminated such conditions or defects to the satisfaction of the water supervisor.

18-309. Unpotable water to be labeled. In order that the potable water supply made available to premises served by the public water supply shall be protected from possible contamination as specified herein, any water outlet which could be used for potable or domestic purposes and which is not supplied by the potable system must be labeled in a conspicuous manner as:

WATER UNSAFE

FOR DRINKING

The minimum acceptable sign shall have black letters at least one-inch high located on a red background.

18-310. Violations and penalty. The requirements contained herein shall apply to all premises served by the town water system whether located inside or outside the corporate limits and are hereby made a part of the conditions required to be met for the town to provide water services to any premises. Such action, being essential for the protection of the water

distribution system against the entrance of contamination which may render the water unsafe healthwise, or otherwise undesirable, shall be enforced rigidly without regard to location of the premises, whether inside or outside the corporate limits.

Any person who neglects or refuses to comply with any of the provisions of this chapter shall be subject to a penalty under the general penalty provision of this code. Each day a violation is allowed to occur shall be a separate offense.